

KEMA TYPE TEST CERTIFICATE OF ENVIRONMENTAL PERFORMANCE

was issued to

Westermo Research and Development AB

Kopparlunden, Sweden

for the test object:

Industrial routing switch

Type: RedFox-5728-F4G-T24G-LVLV
RedFox-5728-E-F4G-T24G-LVLV
RedFox-5728-F16G-T12G-LVLV
RedFox-5728-E-F16G-T12G-LVLV

Ratings:

Rated input voltage (option 1)	28-48 Vdc	EMC immunity location	G/H/P
Rated input voltage (option 2)	28-48 Vdc *	Ethernet ports	12 or 24
Mechanical class	2	Optical ports	16 or 4
Device reliability class	2	EMC emission class	A
* (dual redundant power supply)		Signal ports connections	I/f/h/t

manufactured by

Westermo Research and Development AB

Kopparlunden, Sweden

The test object has successfully passed the required type tests of


IEC 61850-3

The test results are recorded in Certificate No.

1677-22

This Certificate was first issued on 5 October 2022.

Issued by KEMA B.V.



Alessandro Bertani
Services & Smart Technologies Director

